

# JBLTP Hydraulic Modeling and Flow Management Study

Rashi Gupta, PE  
Teri Raasch, PE  
Alyssa DiGirolamo, EIT



# Agenda

- Project background, goals, status
- Hydraulic modeling scenarios: Summary and results
- Hydraulic constraints assessment
- Discussion

# Project Background

- JBLTP has permitted design capacity of 13 MGD AADF:
  - Plant 1: 9 MGD.
  - Plant 2: 4 MGD.
- Average flows have decreased, but peak flows have increased.
- Unknown peak capacity of Plant 1 and Plant 2.
- Decisions on SOCWA's future investments at JBLTP depend on hydraulics.
- Desire to make informed decisions to:
  - Maximize recent improvements.
  - Plan for JBLTP's future improvement projects.

# Project Goals

- Develop and provide plant-wide hydraulic model for SOCWA's future analysis of high-level operational input.
- Determine hydraulic capacity of JBLTP:
  - Recent extreme wet weather events (2017 & 2019).
  - Potential changes in flow from upstream member agency plants.
- Determine hydraulic feasibility and/or constraints of select scenarios.
- Identify hydraulic bottlenecks for potential future projects.


# Project Status

- Data review and plant survey.
- Model development and calibration.
- Scenario development.
- Scenario results and analysis.
- Submit draft Tech Memo and hydraulic model for SOCWA use.
- **Run additional scenarios and incorporate comments.**
- **Submit final Tech Memo and hydraulic model for SOCWA use.**


# Hydraulics Terminology

- Freeboard

- Distance from water surface elevation to top of concrete




- Weir is Free Discharging
  - Downstream water surface is lower than weir crest



- Submerged Weir

- Downstream water surface is higher than weir crest



# Selected Scenarios

| Scenario | Scenario Goals   |
|----------|--|
| 0        | Determine max capacity with 12 inches minimum freeboard <sup>(3)(4)</sup>    |
| 1        | Mimic Title 22 requirements at Plant 1 <sup>(1)</sup>                        |
| 2        | Mimic Title 22 requirements at Plant 2 <sup>(1)</sup>                        |
| 3        | Determine max combined flow with all units in service <sup>(2) (3)</sup>     |
| 4        | Identify where spilling would occur at Plant 1 and Plant 2 <sup>(3)(4)</sup> |
| 5        | Determine max combined flow with typical units in service <sup>(2)</sup>     |
| 6        | Mimic Effluent Management scenario at Plant 1 <sup>(1)</sup>                 |

Notes:

- (1) Maintain 6" free discharge at process weirs and minimum 12" freeboard.
- (2) Maintain 2" free discharge at process weirs and minimum 12" freeboard.
- (3) All units in service.
- (4) Submerged weirs okay.

# Scenario 0: Summary and Results

## Summary

- Determine maximum combined flow to maintain 12-inches of freeboard:
  - Freeboard: Minimum 12-inches.
  - Weirs: Submerged okay.
  - All units in service.

## Results

- Total flow: 20.7 mgd.
  - Plant 1: 12.7 mgd.
  - Plant 2: 8.0 mgd.



# Scenarios 1 and 2

## Summary

- Determine maximum flow through each plant to meet Title 22 requirements:
  - Weirs: Minimum 6-inches free discharge.
  - Freeboard: Minimum 12-inches.
  - Select units in service.

## Results

- Total flow: 11.2 mgd.
  - Plant 1: 6.9 mgd.
  - Plant 2: 4.3 mgd.

| Unit                 | No. In Service Plant 1 | No. In Service Plant 2 |
|----------------------|------------------------|------------------------|
| Bar Screens          | 2 of 2                 | 1 of 1                 |
| Grit Chambers        | 1 of 1                 | 1 of 1                 |
| Primary Clarifiers   | 5 of 6                 | 2 of 3                 |
| Aeration Tanks       | 4 of 4                 | 2 of 2                 |
| Secondary Clarifiers | 8 of 9                 | 3 of 4                 |

# Scenario 3: Summary and Results

## Summary

- Determine max flow through plant to maintain 2-inches free discharge over all process weirs:
  - Weirs: Minimum 2-inches free discharge.
  - Freeboard: Minimum 12-inches.
  - All units in service.

## Results

- Total flow: 16.8 mgd.
  - Plant 1: 9.7 mgd.
  - Plant 2: 7.1 mgd.

# Scenario 4: Summary and Results

## Summary

- Determine max flow through plant before spilling occurs:
  - Weirs: Submerged okay.
  - Freeboard: 0-inches, WSE is equal to top of concrete.
  - All units in service.

## Results

- Total flow: 28.8 mgd.
  - Plant 1: 19.0 mgd.
  - Plant 2: 9.8 mgd.
  - First location at risk: Plant 1 and Plant 2 primary influent channels.
  - Second location at risk: Influent diversion structure.

# Scenario 5: Summary and Results

## Summary

- Determine max flow through plant with typical number of units in service:
  - Weirs: 2 inches free discharging.
  - Freeboard: 12 inches.
  - Select units in service.

## Results

- Total flow: 12.1 mgd.
  - Plant 1: 9.0 mgd.
  - Plant 2: 3.1 mgd.

| Unit                 | No. In Service Plant 1 | No. In Service Plant 2 |
|----------------------|------------------------|------------------------|
| Bar Screens          | 2 of 2                 | 1 of 1                 |
| Grit Chambers        | 1 of 1                 | 1 of 1                 |
| Primary Clarifiers   | 4 of 6                 | 1 of 3                 |
| Aeration Tanks       | 3 of 4                 | 1 of 2                 |
| Secondary Clarifiers | 8 of 9                 | 2 of 4                 |

# Scenario 6: Summary and Results

## Summary


- Determine maximum number of units online at Plant 1 to meet the effluent management scenario of 6.2 mgd:
  - Minimum 6 inches free discharge at process weirs.
  - Minimum 12 inches freeboard.

## Results

- Bar screens: 1 of 2.
- Grit tanks: 1 of 1.
- Primary clarifiers: 4 of 6.
- Aeration tanks: 2 of 4.
- Secondary clarifiers: 6 of 9.


# Hydraulic Constraints Assessment

- Primary Influent Channel:
  - Limited freeboard caused by existing weir and TOC elevations.
  - If more freeboard or flow through plant is needed, raising walls could be evaluated.




# Hydraulic Constraints Assessment

- Plant 1 Secondary Effluent Channel Configuration




- Plant 2 Secondary Effluent Pipe




# Hydraulic Constraints Assessment

- Plant 1 30-inch Raw Sewage Pipe



- Plant 1 Grit Chamber Influent Channel





# Discussion

- Comments/Questions?
- Any additional scenarios of interest?

# JBLTP Hydraulic Modeling and Flow Management Study

Rashi Gupta, PE  
Teri Raasch, PE  
Alyssa DiGirolamo, EIT



# Additional Reference

# // Scenarios Results Summary

| Scenario | Scenario Goals   | Plant 1 Max Flow (MGD) | Plant 2 Max Flow (MGD) | Combined Plant Max Flow (MGD) |
|----------|--|------------------------|------------------------|-------------------------------|
| 0        | Determine max capacity with 12 inches minimum freeboard <sup>(3)(4)</sup>    | 12.7                   | 8.0                    | 20.7                          |
| 1        | Mimic Title 22 requirements at Plant 1 <sup>(1)</sup>                        | 6.9                    | -                      | 11.2                          |
| 2        | Mimic Title 22 requirements at Plant 2 <sup>(1)</sup>                        | -                      | 4.3                    |                               |
| 3        | Determine max combined flow with all units in service <sup>(2)(3)</sup>      | 9.7                    | 7.1                    | 16.8                          |
| 4        | Identify where spilling would occur at Plant 1 and Plant 2 <sup>(3)(4)</sup> | 19.0                   | 9.8                    | 28.8                          |
| 5        | Determine max combined flow with typical units in service <sup>(2)</sup>     | 9.0                    | 3.1                    | 12.1                          |
| 6        | Mimic Effluent Management scenario at Plant 1 <sup>(1)</sup>                 | 6.2                    | -                      | -                             |

Notes:

- (1) Maintain 6" free discharge at weirs and minimum 12" freeboard.
- (2) Maintain 2" free discharge at weirs and minimum 12" freeboard.
- (3) All units in service.
- (4) Submerged weirs okay.

# Hydraulic Constraints Assessment

- Primary Influent Channel:
  - Limited freeboard caused by existing weir and TOC elevations.
  - If more freeboard or flow through plant is needed, raising walls could be evaluated.
- Secondary Effluent Pipe:
  - Generates high headloss.
  - Plant 1: Significant reconfiguration and construction would be required.
  - Plant 2: Upsizing 16-inch section could increase Plant 2 flow by 1 mgd.

# Hydraulic Constraints Assessment

- Plant 1 30-inch raw sewage pipe:
  - Undersized for peak flow, appropriately sized for average flow.
  - Upsizing would improve freeboard at influent junction box, but does not improve overall plant capacity unless downstream constraints are addressed.
- 
- Plant 1 grit chamber influent channel:
  - Generates high headloss.
  - Influent channel could be revised to reduce headloss and improve grit capture.
  - Does not improve overall plant capacity unless other constraints are addressed.